




⚠ See alternate thermostat sheet.
Set heat anticipator at .40A

⚠ For 208V operation move this
wire to 208V transformer tap.

501949