



⚠ IF THERE IS AN X1 AND X2 TERMINAL ON 18740110, JUMPER THEM TOGETHER AND CONNECT FROM C TO EITHER ONE.

⚠ FOR 200V OPERATION MAKE THIS WIRE TO 200V TRANSFORMER TAP.

⚠ 400V - 40/440 CAPACITOR
500V - 45/440 CAPACITOR