



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBR	INDOOR BLOWER RELAY
CB2	CIRCUIT BREAKER #2	LAB	LOW AMBIENT BYPASS CONTROL
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
COMP	COMPRESSOR	LPB	LOW PRESSURE BYPASS
DFC	DEFROST CONTROL	LPC	LOW PRESSURE CONTROL
EBR	EMERGENCY HEAT RELAY	LS	LIMIT SWITCH
GN0	EQUIPMENT GROUND	DFC	OUTDOOR FAN MOTOR
H1	HEAT STRIP #1	OFM	OUTDOOR FAN MOTOR
H2	HEAT STRIP #2	OFR	OUTDOOR FAN RELAY
HC1	HEATER CONTACTOR #1	PL1	PLUG #1
HC2	HEATER CONTACTOR #2	RV	REV. VALVE SOL.INDOIT
HPC	HIGH PRESSURE CONTROL	T	TRANSFORMER
IBC	INDOOR BLOWER CAPACITOR	TB	TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TBL	LOW VOLTAGE TERMINAL BLOCK
		TCD	THERMAL CUTOFF

△ , **△** LABELED WIRES CONNECT IF NO OPTIONS USED.

△ MOVE RED WIRE TO 208V TAP FOR 208V OPERATION

△ RED (LOW) BLACK (HIGH) WERE APPLICABLE

△ REMOVE JUMPER FOR OUTDOOR THERMOSTAT

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	—	- - -	- - -
LOW VOLTAGE	—	- - -	- - -
ACCESSORY	—	- - -	- - -

COLOR CODE					
BK	BLACK	Y	YELLOW	V	VIOLET
BR	BROWN	G	GREEN	(PR)	PURPLE
R	RED	BL	BLUE	GY	GRAY
O	ORANGE	W	WHITE	(S)	SLATE
		PK	PINK	T	TAN
		L	LAVENDER		

BARD MFG. CO.
4096-233 A