


For Vent Wiring or controller/thermostat connections, see literature packet or go to www.bardhvac.com

460-60-3
Per Nameplate

L1 L2 L3
---Hi Voltage Field Connection
---Hi Voltage Field Connection
---Hi Voltage Field Connection



WARNING
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

DANGER
ELECTRICAL SHOCK HAZARD
DISCONNECT POWER BEFORE SERVICING.

High Voltage	Factory	Field	Optional
Low Voltage			

Wire Identification numbers for Bard (99) use only.
4096-391

A → **A**
Same Letter Designated Wires Connect if Option Not Used
A No Control Option
B & *C* Only LAC Option

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED