



For Vent Wiring or controller/thermostat connections, see literature packet or go to www.bardhvac.com

460-60-3 Per Nameplate L1 L2 L3
 Hi Voltage Field Connection
 Hi Voltage Field Connection
 Hi Voltage Field Connection

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED

A → **A**
 Same Letter Designated Wires Connect if Option Not Used
 "A" No Control Option
 "B" & "C" Only LAC Option
 "D" Control not required in all units

WARNING
 USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

DANGER
 *ELECTRICAL SHOCK HAZARD
 *DISCONNECT POWER BEFORE SERVICING.

	Factory	Field	Optional	Wire Identification numbers for Bard use only.
High Voltage				99
Low Voltage				

4217-301 A